

Summary of Sampling

29 water samples were collected from 13 sources. All results are shown in Table 1.1.

Table 1.1

Sample ID	Sample Location Description	Fixture Type	Sample Type	Concentration
IS 1A	Kindergarten - Rm. 146 - Sink/Fountain Combo	S - Sink	First Draw	3.94 ppb
IS 1B	Kindergarten - Rm. 146 - Sink/Fountain Combo	DF - Drinking Fountain	First Draw	ND
IF 1	Kindergarten - Rm. 146 - Sink/Fountain Combo	DF - Drinking Fountain	Flush	ND
IS 2A	pre-K - Rm. 144 - Sink/Fountain Combo	DF - Drinking Fountain	First Draw	ND
IS 2B	pre-K - Rm. 144 - Sink/Fountain Combo	S - Sink	First Draw	ND
IF 2	pre-K - Rm. 144 - Sink/Fountain Combo	DF - Drinking Fountain	Flush	ND
IS 3	pre-K - Room 147	S - Sink	First Draw	ND
IF 3	pre-K - Room 147	S - Sink	Flush	ND
IS 4A	pre-K - Rm. 142 - Sink/Fountain Combo	DF - Drinking Fountain	First Draw	ND
IS 4B	pre-K - Rm. 142 - Sink/Fountain Combo	S - Sink	First Draw	ND
IF 4	pre-K Rom. 142 - Sink/Fountain Combo	S - Sink	Flush	ND
IS 5	Corridor by Kitchen - Left/Upper	DF - Drinking Fountain	First Draw	ND
IF 5	Corridor by Kitchen - Left/Upper	DF - Drinking Fountain	Flush	ND
IS 6	Corridor by Kitchen - Right/Lower	DF - Drinking Fountain	First Draw	ND
IF 6	Corridor by Kitchen - Right/Lower	DF - Drinking Fountain	Flush	ND
IS 7	Kitchen - West	KS - Kitchen Sink	First Draw	4.04 ppb
IF 7	Kitchen - West	KS - Kitchen Sink	Flush	ND
IS 8	Corridor by Small Gym - Left/Upper	DF - Drinking Fountain	First Draw	ND
IF 8	Corridor by Small Gym - Left/Upper	DF - Drinking Fountain	Flush	ND
IS 9	Corridor by Small Gym - Right/Lower	DF - Drinking Fountain	First Draw	ND
IF 9	Corridor by Small Gym - Right/Lower	DF - Drinking Fountain	Flush	ND
IS 10	Corridor by Elevator	DF - Drinking Fountain	First Draw	ND
IF 10	Corridor by Elevator	DF - Drinking Fountain	Flush	ND
IS 11	Outside Restroom (114)	DF - Drinking Fountain	First Draw	ND
IF 11	Outside Restroom (114)	DF - Drinking Fountain	Flush	ND



Lead Testing in Drinking Water**Immanuel Lutheran School**

Sample ID	Sample Location Description	Fixture Type	Sample Type	Concentration
IS 12	Lower Level by Restroom 005 - Left/Upper	DF - Drinking Fountain	First Draw	ND
IF 12	Lower Level by Restroom 005 - Left/Upper	DF - Drinking Fountain	Flush	ND
IS 13	Lower level by Restroom 005 - Right/Lower	DF - Drinking Fountain	First Draw	ND
IF 13	Lower level by Restroom 005 - Right/Lower	DF - Drinking Fountain	Flush	ND
ND = None Detected				

